



MODEL **301GAS™**  
Gas burner

**Supplement 1**  
**Massachusetts Code**

(Use with Instruction manual MN301GAS)

**Massachusetts applications**

1. For 301GAS burner applications in the Commonwealth of Massachusetts, the burner input may not exceed 999,999 Btuh.
2. Model 301GAS burners for use in the Commonwealth of Massachusetts must be equipped with Carlin 60200FRN non-recycling primary controls. These controls will lockout on flame failure.

**WARNING**

Replace the original content in the Instruction manual with the information provided in this supplement. Failure to follow these guidelines could result in severe personal injury, death or substantial property damage.

**Replace the following Instruction manual content:**

1. Page 11, Figure 11 — Replace wiring diagram with diagram given in this supplement.
2. Page 22, Item 16 — Change description to “Pipe nipple, schedule 40 steel, 1”NPT x 3” long.”

Figure 11 Wiring diagram — 301GAS burner with 60200FR primary control (Replaces Figure 11, page 11)

